



Princeville *at Hanalei* Community Association

Enhancing the Quality of Life and Princeville Experience for its Members
Community Design Committee

Owner Name: _____ Email _____ Cell: _____

Property Address: _____ Date: _____

PROPANE APPLICATION

Contractor: _____ Email: _____ Cell: _____

Projected work dates: _____

Type of Tank: 100lb vertical 124 gallon horizontal tank

Type of Material Enclosure: _____

Dimensions of enclosure: _____

Please Attach:

- A Copy of property site plan, with location of the propane tank pad.
- A photo of the location.

Per CDC Rules:

- The enclosure will screen the tank from view from all sides to a height limit of 3 feet. The materials and color will be compatible with the main structure.
- Propane tanks will be located 10 feet from side property lines and 20' from front and 30' from rear property lines.
- Propane tanks will be a minimum of 5 feet from electrical sources.
- The fuel truck will be visible at all times during refueling with the hose length a maximum of 60 feet.
- Tanks will be located a minimum of 3 feet from an operable door or window.

Once complete, call the PHCA office (808) 826-6687 to schedule a Final Inspection.